



Mechanical Tolerance Guidelines for Hydroelectric Generators

VibroSystM guidelines are based on 15 years experience with dynamic air gap measurement and data interpretation, as well as on the guidelines established by the Canadian Electrical Association (CEA) and Hydro-Québec. VibroSystM guidelines apply to dynamic measurements obtained with its monitoring equipment.

The values are conservative[†] by design and for reference only; further results analysis and other considerations are recommended before initiating an intervention on the machine. With the Results Interpretation Service (RIS), VibroSystM offers its expertise in data analysis of hydroelectric machine condition and behavior.

Parameters	Deviation [◇]		
	Assembly	Acceptable	Critical
Rotor-Stator Mechanical Tolerances			
Maximum Air Gap Variation	< 13% [†]	13 — 30%	> 30%
Stator Roundness	< 7%	7 — 20%	> 20%
Stator Concentricity	< 5%	5 — 10%	> 10%
Rotor Roundness	< 6%	6 — 10%	> 10%
Rotor Concentricity	< 1.2%	1.2 — 4%	> 4%
Minimum Air Gap	> 85%	85 — 50%	< 50%
Vibration			
Shaft (0—300 rpm)	< 102 / 4.0 [*]	102 — 305 / 4.0 — 12.0	> 305 / 12.0
Shaft (300—1200 rpm)	< 51 / 2.0	51 — 152 / 2.0 — 6.0	> 152 / 6.0
Stator Core	< 25 / 1.0	25 — 51 / 1.0 — 2.0	> 51 / 2.0
Stator Frame	< 25 / 1.0	25 — 127 / 1.0 — 5.0	> 127 / 5.0

[◇] Table for dynamic measurements obtained with VibroSystM monitoring equipment

[†] Air Gap expressed in percentage (%) of nominal air gap at Static—Cold

^{*} Vibration expressed in µm / mils Peak-Peak

References Guide for Erection Tolerances and Shaft System Alignment, Canadian Electrical Association (CEA)
Guide technique – Division Études et Normalisation, VP Ingénierie, Hydro-Québec
Latest revision by Genexpert for VibroSystM in January 2005

Definitions on back of page



Definitions:

Tolerance	<i>Permissible zone</i> within which a point, axis or plane of a component must be located. Unless otherwise indicated, this tolerance zone is centered on the reference point, line or plane. This reference point, line or plane is assumed accurate with no tolerance.
Deviation	<i>Measured or measured and calculated distance</i> of a point, line or plane on a component being verified from the reference point, line or plane.
Assembly	At commissioning of a new or refurbished generator and up to five years in operation.
Acceptable	For generator in service for five to fifteen years.
Critical	For which immediate actions are required.
Nominal Air Gap	Designed air gap value at static–cold (as indicated on manufacturer drawings).
Air Gap Variation	Difference between maximum inside radius of the stator and minimum outside radius of the rotor (maximum gap) measured on a single plane from the rotor rotation axis ³ .
Average Air Gap	Average of all measured and calculated air gaps for all rotor poles.
Stator Concentricity (Center Offset)	Difference between best stator center (geometric center) and rotor rotation axis (reference) measured on the same plane and calculated from the rotor reference pole ³ .
Stator Roundness	Difference between maximum inside radius and minimum inside radius measured from the rotor rotation axis.
Rotor Concentricity (Center Offset)	Difference between best rotor center (geometric center) and rotor rotation axis (reference) calculated from the outside radius of each pole on the same plane facing sensor #1.
Rotor Roundness	Difference between maximum outside radius and minimum outside radius along the same horizontal plane facing sensor #1.
Stator Core Vibration	Measured between the core and the frame.
Stator Frame Vibration	Measured between the frame and the sole plate.
Acceptable Air Gap Runout	Acceptable variation in air gap readings of 0.13 mm / 5 mils attributed to shaft vibration (75%), and stator vibration (25%).
Static–Cold	Machine stopped and cooled down to ambient temperature.
Full Load–Hot	Machine in normal operating condition at full load and temperature stabilized after a minimum of 3 hours in operation.

¹ Two reasons for conservative values:

- 1) air gap sensor may not be installed at true minimum gap location,
- 2) unknown manufacturers safety factor margins

² 1 mm ≈ 39.4 mils / 1 mil ≈ 0.0254 mm or 25.4 μm

³ VibroSystM default references:

- rotor pole #1,
- 0° axis at upstream location (top of polar graph),
- virtual rotational axis for pole #1 facing sensor #1 (usually near upstream)

For more information, contact VibroSystM at:
2727 East Jacques-Cartier Blvd
Longueuil (Quebec) J4N 1L7 CANADA
Tel.: +1 450 646-2157 • +1 800 663-8379 (US only)
Fax: +1 450 646-2164
Email: sales@vibrosystem.com
www.vibrosystem.com